


**Missouri Department of Transportation**  
*David B. Nichols, Director*

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

**ADDENDUM 001**  
**Fulton Maintenance Building Metal Siding & Roof**  
**Request for Bid 9-140709TV**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing and including it** with the original bid. The due date for receipt of bids remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Name: Tom Veasman Title: Sr. General Services Specialist
Bidder Signature	Department of Transportation  
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: July 1, 2014

Vendor Question: The panel specified for this project is a screw down panel (exposed fasteners). Also, this panel is not for low pitches as shown on the shop portion of the building. The specs indicated exposed fasteners on vertical surfaces only. Is the low pitch portion of the building supposed to be standing seam product contrary to what is specified? Please clarify what panel is desired for the different building roof conditions.

Answer: MoDOT has successfully used exposed fasteners before with this roof detail. Thus, no standing seam roof is required. Use screw down 26 gauge roofing.

Vendor Question: 07411 Metal Roof and Wall Panels – Part 2 Paragraph 2.2 A.3. references “Material Galvalume steel sheet” while 2.3 A. references galvanized steel sheets. Assuming galvalume will be acceptable?

Answer: YES. McElroy Roofing has Galvalume under the roof paint (Kynar 500).

Vendor Question: 07465 Aluminum Soffit Panels – Part 2 Paragraph 2.1 A. references aluminum sheets. I understand that a Kynar finish is not available for aluminum. Is there a reference that directs us as to what type of paint that is specified for the soffit and trim?

Answer: For soffits and trim with Kynar 500 paint see Atas International & Pac-Clad.

